

E-2080-1-P - WIRING DETAIL

2080 SERIES CENTER-ROLL® DIVIDER CURTAIN MAXIMUM 60'-0" LENGTH OR 1500 Sq. Ft.

THREE WIRES (UP, DOWN, NEUTRAL)
FROM POWR-TOUCH® RELAY PANEL
(JUMPER IN RELAY PANEL INSTALLED IN "120VAC" POSITION)

LOCATE JUNCTION BOX
WITHIN 3'-0" FROM END
OF CURTAIN (BY OTHERS)

POWER
REEL

WALL OR TORQUE BELT
GUIDE (ONE END OF
CURTAIN)

3" DIA. CENTER BATTEN TUBE

ELECTRIC MOTOR

SINGLE MOTOR
POWR-TOUCH® OPERATION

CENTER-ROLL® DIVIDER CURTAIN FIELD WIRING DETAIL (WITH POWR-TOUCH® OPERATION)

POWER SOURCE REQUIREMENTS (ELECTRIC MOTOR)

- 115 VOLTS
- 5 AMPS
- SINGLE PHASE, 60 Hz.

WIRING OF ALL ELECTRICAL COMPONENTS
SHALL BE IN ACCORDANCE WITH NATIONAL
AND LOCAL ELECTRICAL CODES, AND IN
ACCORDANCE WITH THESE INSTRUCTIONS.

NOTE - ELECTRICAL CONTRACTOR TO PROVIDE
FIELD WIRING AS REQUIRED TO MEET ALL LOCAL
ELECTRICAL CODES.

FIELD-WIRING DETAIL FOR CENTER-ROLL® DIVIDER CURTAIN MODELS (FOR UNITS EQUIPPED WITH POWR-TOUCH® OPERATION)

MODEL 92081-___ WALL GUIDE OPERATION DIVIDER CURTAIN (MAXIMUM 60'-0" LG.)

MODEL 92082-___ TORQUE BELT OPERATION DIVIDER CURTAIN (MAXIMUM 60'-0" LG.)

porter®

888-277-7778 PORTER@PORTERATHLETIC.COM
© COPYRIGHT 2014 PORTER ATHLETIC - ALL RIGHTS RESERVED

PROJECT NUMBER _____

PROJECT NAME _____

porter

WWW.PORTERATHLETIC.COM/FACILITY

FIELD WIRING SHEET

E-2080-1-P

6/23/2014